



Conservation and Generation: Focusing on Energy to Save Money at Calvin College

Trevor Nyeholt, Erik Karlson, Cam Richman, Tyson Butler

Engineering 333

December 6, 2017

Natural Gas Savings Project



ENGR 333-A
Trevor Nyeholt and Erik Karlson

The Problem

Calvin College spent \$836,000 on natural gas in 2016



http://www.wzzm13.com/img/resize/content.wzzm13.com/photo/2017/02/15/Calvin%20college%20sign.3_1487195906153_8522173_ver1.0.jpg?preset=534-401

Fossil Consumption & Potential Saving



Figure from Sightlines 2017 Report

What would it take to save Calvin
\$75,000 per year on natural gas costs?

Academic Buildings



<https://calvin.edu/contentAsset/image/869e8731-49b2-4e7e-a1b1-0de4926c709f/>

Dorms and Dining Halls



<https://static1.squarespace.com/static/507db947e4b046d343cd164/t/55fad97ce4b081c8>

Spoelhof Fieldhouse Complex



http://www.recmanagement.com/images/201005/201005_aw_3d_01.jpg

Finance



<https://www.istockphoto.com>

Boilers



https://content.invisionic.com/r262316/monthly_2017_03/boiler.jpg.ea4907d8f723

Projects



Boilers



Academic



Dorms/ Dining



Fieldhouse

Increase Boiler Efficiency	Replace Windows	Additional Roof Insulation	Additional Roof Insulation
Replace Kewanee Boilers	Standard Temp	Adjust Radiator Fins	Behavioral Changes
--	--	Replace Windows	Standard Temp

Best Cost-Saving Projects

- Improving and Replacing the Boilers



<https://www.google.com/search?q=boiler&source=lnms&tbn=isch&sa=X&ved=0ahUKEwjht>

Best Cost-Saving Projects


- Improving and Replacing the Boilers
- Standardizing Building Temperature



http://www.pgecurrents.com/?attachment_id=13547 By Chip Buchanan


Best Cost-Saving Projects

- Improving and Replacing the Boilers
- Standardizing Building Temperature
- Adjusting the Dorm Radiator Fins




<https://4.iimg.com/data4/FT/MB/MY-8338283/industrial-radiator-cores-500x500.jpg>

Boilers




<http://marinersgalaxy.com/2013/03/different-types-of-marine-boilers-and.html>

Boilers-Location



Boilers-Increase Maintenance


Fire Tube (Kewanee)



http://heating.danfoss.com/PCMPDF/BC_Kaupp_report_VFGIA102.pdf

Efficiency
65% → 67%

Water Tube (Hurst)



http://heating.danfoss.com/PCMPDF/BC_Kaupp_report_VFGIA102.pdf

Efficiency
78% → 80%


Boilers-Increase Maintenance



<http://i2.wp.com/optimiseheatandsteam.com/wp-content/uploads/2015/04/Boiler-Cleaning.jpg?resize=4303%2C3247>

Annual Cost: \$4,000
Net Annual Savings: \$11,000

Boilers-Add Economizers and Controls




https://www.energir.com/~media/Images/Affaires/Gif_appareils/Gif_appareils_ang/Boiler_stack_economizer_en.gif?h=240&la=en&w=279

Implementation Cost: \$45,000
Annual Savings: \$10,000



Implementation Cost: \$5,000
Annual Savings: \$5,000

Boilers-Replace Kewanee



https://c1.staticflickr.com/5/4062/4430326044_cc8280f511_b.jpg

Kewanee Boilers

- Fire Tube Boilers
- 67% Efficiency



<https://www.hurstboiler.com/images/ohio-special.png>

Hurst Boilers

- Water Tube Boilers
- 80% Efficiency

Implementation Cost: \$300,000

Annual Savings: \$30,000

Building Temperature Standard


Example:

Grand Valley State University Policy


PROCEDURES

During the winter season the heating controls are set at a maximum of 70°F. During the summer season the minimum cooling temperature will be 76°F. Facilities Services will respond to hot/cold calls to ensure that systems are running properly, but will not adjust the temperatures to levels outside of the standards

<https://www.gvsu.edu/policies/policy.htm?policyId=E677FA8A-E5C3-83>



Window Area Totals



Building Temperature Standard



Academic Buildings

73°F → 68°F


PE Complex

73°F → 68°F

Implementation Cost: \$0

Annual Savings: \$13,500


Dorm Radiators




From Physical Plant Floor Plans



Dorm Radiators






Implementation cost: \$0
 Annual Savings: \$11,000
 Payback: 0 Years

\$45,000
 \$10,000
 4.5 Years

\$5,000
 \$5,000
 1 Year




Implementation cost: \$300,000
 Annual Savings: \$30,000
 Payback: 10 Years


\$0
 \$13,500
 0 Years


\$50,000
 \$19,800
 2.5 Years


Total Annual Savings (\$)	\$89,300
Implementation Cost (\$)	\$400,000
Payback (Years)	4.5




















\$75k Class Target









Co-Gen Plant Energy Savings

ENGR 333-B


Cam Richman, Tyson Butler

What would it take for Calvin to save \$150k/year on energy costs using a new on-site co-generation plant?



© Devon Loerap

What is a Co-generation Plant?



<https://www.google.com/search?biw=1385&bih=803&tbm=isch&sa=1&ei=WekIWsmQlcvKjwT1qqnYBA&q=coge>

Calvin's Old Co-generation Plant





<https://www.google.com/search?q=ge+>

Engine Selection



<https://www.google.com/search?q=>

Interconnections



<https://www.google.com/search?q=consumers+ene>

Natural Gas /Electricity Savings




<https://www.google.com/search?q=>

CO₂ Savings




<https://www.google.com/search?q=finance+pict>

Finances



Main Electricity Loop


From Burton St. Substation



Main Heating Loop

To DeVos and Prince

Calvin College 2016 Electricity Consumption



Calvin College Electrical Consumption



<https://calvin.edu/news/archive/under-the-lights>

2010-2016 Data:

- Electricity: 25,000,000 kWh/yr
- Peak usage: 5250 kW
- Min usage: 1340 kW

Electrical Price Variation

- Simplified Electricity Cost

- Off-peak \$0.07/kWh (7pm-11am)
- Peak summer \$0.14/kWh (11am-7pm)
- Peak winter \$0.09/kWh (11am-7pm)

Jan	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6	7	7	7	6	6	5	5	5
Feb	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6	7	7	7	6	6	5	5	5
Mar	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6	7	7	7	6	6	5	5	5
Apr	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6	7	7	7	6	6	5	5	5
May	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6	7	7	7	6	6	5	5	5
Jun	1	1	1	1	1	1	2	2	2	2	2	2	3	3	4	4	4	3	3	2	2	2	2	1
Jul	1	1	1	1	1	1	2	2	2	2	2	2	3	3	4	4	4	3	3	2	2	2	2	1
Aug	1	1	1	1	1	1	2	2	2	2	2	2	3	3	4	4	4	3	3	2	2	2	2	1
Sep	1	1	1	1	1	1	2	2	2	2	2	2	3	3	4	4	4	3	3	2	2	2	2	1
Oct	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6	7	7	7	6	6	5	5	5
Nov	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6	7	7	7	6	6	5	5	5
Dec	5	5	5	5	5	5	5	5	5	5	5	5	5	5	6	6	7	7	7	6	6	5	5	5
	12:00 AM	1:00 AM	2:00 AM	3:00 AM	4:00 AM	5:00 AM	6:00 AM	7:00 AM	8:00 AM	9:00 AM	10:00 AM	11:00 AM	12:00 PM	1:00 PM	2:00 PM	3:00 PM	4:00 PM	5:00 PM	6:00 PM	7:00 PM	8:00 PM	9:00 PM	10:00 PM	11:00 PM

Engine Considerations

- Engine cycle type
 - Brayton or Otto
- Company
 - GE
 - Enerblu
 - Kawasaki



<https://upload.wikimedia.org/wikipedia/commons/thumb/f/fff/General>




https://pbs.twimg.com/profile_images/850053964322164736/nR5qG5Bh_400x400.jpg




https://www.google.com/search?q=kawasaki+logo&source=inms&tbn=isch&sa=X&ved=0ahUKEwiej9KsvenXAhWC8YMKHVHEBNgQ_AUICigB&biw=1

Engine Considerations




Final Engine Selection

- Model: GE's Jenbacher 4 J416 GS-B86
- Power: 1137 kW
- Fuel Cost: 3.8¢ /kWh
- Cost of Installed Engine: \$1.4 million



https://www.google.com/search?q=ge+jenbacher+j416&rlz=1C1GCEA_enUS773US773&source=lnms&tbn=isch&sa=X&ved=0ahUKEwjG7

Max Day Electrical Consumption




Installations

Option 1:

Previous Co-gen Location

- Pros:
 - Existing infrastructure
- Cons:
 - Size constraints
 - Installation
 - Maintenance



Option 1

Option 2



Proposed Location

Installations

Option 2:

Student Union

- Pros
 - Expansion plans
 - Redundancy
- Cons
 - Infrastructure
 - Eyesore



Proposed Location


Option 3:


East of Commons

- Pros
 - Expansion plans for loading docks
 - Heat/electricity loop availability
- Cons
 - Sound Pollution



Sound Considerations





http://secondnature.org/wp-content/uploads/Commitment-Timeline_Climate_Orange.png

*"The earth is the LORD's, and the fullness thereof;
the world, and they that dwell therein."*
Psalm 24:1 (KJV)

CO₂ Emissions



<https://d2v9y0dukr6mq2.cloudfront.net>



<http://www.financeappraise.com>

Primary Emissions

- Substances/waste gas streams emitted directly; through on-site practices

Secondary (Embodied) Emissions

- Substance/waste gas streams emitted indirectly; through off-site practices


Present CO₂ Emissions

Currently at Calvin College


- 100% of electricity sourced from Consumers Energy

Consumers Energy CO₂ Emissions


- **0.758 kg CO₂ /kWh**



Cogeneration Emissions



Cogeneration Emissions




Offset of Boiler Emissions

- “Waste” heat from Co-gen
- Reduce boiler operations
- Minimize boiler exhausts



<https://www.google.com/search?q=boiler&source=lnms&tbm=isch&sa=X&ved=0ahUKEwjht>

Cogeneration Emissions




Engine Finance

Total upfront Engine Cost : \$1,400,000

Assumptions

- Includes lifetime spare parts
- Calvin Installation



https://www.google.com/search?q=ge+jenbacher+j416&rlz=1C1GCEA_enUS773US773&source=lnms&tbn=isch&sa=X&ved=0ahUKEwjG7

Interconnections Finance

Total Infrastructure Cost: \$95,000

Expensive Components


- Concrete
- Cinder Blocks
- Roofing
- Gas Line
- Piping



<https://www.google.com/search?q=building+materials&rlz=1C1GCEA>

Gas Price Fluctuations

- Cost of natural gas
 - \$0.53 /100 ft³ → \$0.038 /kWh




Cost Savings Calculations

Electricity Savings

- Considerations
 - Peak and Off Peak Rates
 - Winter and Summer Peak Rates
- 90 Percent Utilization

Gas Savings

- Boiler Usage



https://www.google.com/search?q=consumers+energy+logo&rlz=1C1GCEA_enUS773US773&tbm=isch&s

Total Savings

Electricity Savings:	\$319,000 /yr
Natural Gas Savings:	\$187,000 /yr
Calvin Maintenance Cost:	(\$2,000) /yr
Total Savings:	\$504,000 /yr



Conclusion

	<u>Goal</u>	<u>CO₂</u>	<u>Energy</u>
Section A:	✓	906 MT/yr	\$89,000/yr
Section B:	✓	18,950 MT/yr	\$504,000/yr

Acknowledgements

- Phil Beezhold, former Director of Physical Plant at Calvin College
- Jack Phillips, Associate Director of Mechanical
- Professor Richard De Jong, Sound/Vibrations Consultant
- Jared Cherni, GE Power Sales and Business Development Manager
- Professor Matthew Heun, ENGR 333 Instructor
- Engineering 333 Classes

Questions?

Appendix

Section B: Co-gen Energy Savings

Financial Savings

Option 1: Fully Funded Co-gen

Annual Savings:

\$504,000

Option 2: Bank Loan


Bank Loan: 4 years, 5% interest

Life of Cogen: 20 years


Avg Annual Savings:

\$420,000 (4 year payback)

Electricity Savings Sensitivity



CO₂ Finances



- Carbon Difference
 - + 199 tons (Installation)
 - - 4,498 tons/year (Operation)
- Emission breakeven point
 - 16.1 days

CO₂ Finances

- Total Savings
\$22,000 per year
- Assumptions
 - \$5/ton carbon trade value



[https://www.google.com/search?q=co2+images&rlz=1C1GCEA_enUS773US773&tbm=isch&source=iu&ictx=1&fir=0kTxa162UWr98M%253A%](https://www.google.com/search?q=co2+images&rlz=1C1GCEA_enUS773US773&tbm=isch&source=iu&ictx=1&fir=0kTxa162UWr98M%253A%253A)